

### **The following notes should be included in the Roadway Cover Sheet**

1. NCDOT Standard Specifications are used for construction of the roadways, including the NCDOT SuperPave Manual.
2. Section 1018 of the NCDOT Standard Specifications will be used for the acceptance of borrow material being used for embankments backfill or other intended uses.
3. A 48 hour notice for scheduling is required for the proof roll. Please allow adequate time for the inspector to perform grade checks on the subgrade and ABC.  
  
A proof roll will be performed prior to:
  - Placement of curb and gutter.
  - Placement of ABC.
  - Placement of asphalt.
4. Aggregate Base Course shall be provided from approved sources as outlined in Section 1010 of the NCDOT Standard Specifications.
5. A Pre-Paving meeting will be required prior to any paving.
6. A NCDOT approved Job Mix Formula must be submitted for approval prior to paving.
7. Asphalt mixes and depths will adhere to the typical section for roadways approved in the construction drawings. Minimum depths unless otherwise noted will be 2 ½" of I 19.0B placed in one lift and 2" of SF 9.5A placed in two lifts. The first lift of SF 9.5A will be placed immediately on the I 19.0B, and the second lift will be placed prior to acceptance of the road. Drainage will be required on the roadway during the transition of the two lifts of SF 9.5A.
8. A Pre-Pour meeting will be required prior to any concrete pours.
9. A NCDOT approved Mix Design must be submitted on a NCDOT form 312U prior to placing any concrete.
10. Refer to detail sheets for the proper installation requirements for storm piping using NCDOT Standard Drawing 300.01.
11. The contractor is required to submit a video of the storm system prior to placing asphalt on the project.
12. NCDENR Erosion Control Permit is required on-site during construction. NCDENR will be inspecting the project for compliance with the erosion control plan.
13. The approved typical section includes a shoulder behind the curb and gutter on both sides of the roadway. The shoulder must be preserved during grading of adjacent properties.
14. Only street legal vehicles, legally loaded appropriately for the hauling vehicle, shall be used to transport construction materials on City streets.
15. Notify the City of any work being performed on the weekends. No work requiring testing or observation by the City will be permitted without written permission.
16. Noise Ordinance: 7:00am to 9:00pm – weekdays, 8:00am to 9:00pm weekends.