



BACKFLOW DEVICE	A
4"	6'-3"
6"	9'
8"	11'-2"

WATER MAIN SIZE	B
6"	17"
8"	19"
12"	22"
16"	26"
24"	32"

WATER MAIN SIZE	MIN. BACKFLOW DEVICE SIZE	MIN. END OF LINE BLOWOFF
6" OR 8"	2"	2"
12"	4"	2.5
16"	6"	4"
24"	8"	6"



## BACKFLOW PREVENTION BY-PASS CONNECTION FOR FILLING NEW WATER MAINS

DATE: JULY 9, 2015

**W-BF-05**