



NOTES:

1. ALL CONCRETE TO BE 3600 P.S.I., 6" MIN. THICKNESS
2. ALL DRIVEWAYS MUST MEET THE CURRENT CITY DRIVEWAY REGULATIONS AND NCDOT REQUIREMENTS FOR SPACING, SIGHT DISTANCE AND OFFSETS FROM PROPERTY LINES AND INTERSECTIONS.
3. ALL CURB OR CURB AND GUTTER AND SIDEWALKS ARE TO BE REMOVED TO THE NEAREST JOINT BEYOND NEW CONSTRUCTION OR CUT WITH A SAW AND REMOVED. SAW CUT OR JOINT TO BE PERPENDICULAR TO EDGE OF EXISTING PAVEMENT.
4. FOR PLANTING STRIP LESS THAN 4- FEET, SLOPE SIDEWALK TO MEET GRADE OF ENTRANCE. SIDEWALK GRADE SHALL BE 12:1 MAX.
5. RADIUS REQUIREMENTS -
RESIDENTIAL: MIN.- 3'
COMMERCIAL/INDUSTRIAL: MIN.-6' MAX.-30'
6. NO UTILITIES PERMITTED IN DRIVEWAYS

B
PLAN VIEW



| DRIVEWAY CLASSIFICATION | | |
|------------------------------------|---------|---------|
| TYPE DRIVEWAY | MINIMUM | MAXIMUM |
| RESIDENTIAL | 12' | 20' |
| COMMERCIAL/INDUSTRIAL MULTI-FAMILY | 24' | 36' |
| COMMERCIAL/INDUSTRIAL ONE-WAY | 15' | 20' |



**DRIVEWAY ENTRANCE
RADIUS TYPE**

DATE: JULY 9, 2015

R-DR-01