



NOTES:

- A. THE PIPE SHALL BE A MINIMUM DIAMETER OF 15" REINFORCED CONCRETE OR APPROVED BY KANNAPOLIS AND A MINIMUM LENGTH OF 20'.
- B. A LARGER PIPE SIZE MAY BE REQUIRED IF DETERMINED BY A PROFESSIONAL ENGINEER.
- C. THE LENGTH OF PIPE REQUIRED SHALL BE THE AMOUNT NEEDED TO EXTEND (1') BEYOND THE TOE OF A 2:1 SLOPE. SEE SECTION DETAIL.
- D. NO UTILITIES IN DRIVEWAY, MUST BE MIN. 3' FROM DRIVEWAY
- E. DITCH SHOULD BE INSPECTED BY PUBLIC WORKS BEFORE PIPE IS INSTALLED.



SINGLE FAMILY RESIDENTIAL DRIVEWAY
WITH NO CURB & GUTTER

DATE: JULY 9, 2015

R-DR-03