



PLAN

NOTE:

1. TRANSITION FROM 2'-6" STANDARD CURB TO VALLEY CURB AT A DRAINAGE INLET ONLY.
2. TRANSITIONS SHORTER THAN 10' SHALL BE APPROVED BY THE CITY ENGINEER. UNDER NO CIRCUMSTANCE SHALL A TRANSITION BE SHORTER THAN 3'-6".

NOT TO SCALE