



APPROVED 3/4" - 2" RPPA

BUCKNER	150-RP
CONBRACO	SERIES 40-200
FEBCO	MODEL 825Y
	MODEL 825YA
HERSEY	MODEL FRP11
WATTS	SERIES 909 (3/4"-1")
	" 909M1 (1/4"-2")
	" 009QT
	" 0009QT
	" 0009A QT
MILKINS	MODEL 9T5XL

- NOTES:**
1. REDUCED PRESSURE PRINCIPLE ASSEMBLIES (RP) MUST CONFORM TO CITY OF KANNAPOLIS CROSS CONNECTION CONTROL POLICY.
 2. 3/4" - 2" RP INCLUDES SHUT OFF VALVES #1 AND #2 AS PART OF THE ASSEMBLY. NO SUBSTITUTIONS SHALL BE PERMITTED.
 3. ALL RP INSTALLATIONS SHALL BE INSTALLED IN A PROTECTIVE COVERING APPROVED BY THE CITY OF KANNAPOLIS BACKFLOW PREVENTION ADMINISTRATOR. RIGID PIPE AND FITTINGS SHALL BE 3/4" TO 2" BRASS OR K-COPPER.
 4. TEST COCK #1 SHALL BE UPSTREAM OF SHUT OFF VALVE #1 AND IS PART OF THE APPROVED ASSEMBLY.
 5. HEATED ENCLOSURES ARE REQUIRED FOR ALL FIRE LINE CONNECTIONS.



KANNAPOLIS
PUBLIC WORKS

BACKFLOW PREVENTION
3/4"-2" REDUCED PRESSURE PRINCIPLE
ASSEMBLY (RP)

DATE: 21 MAY 12
W-BF-01