




**KANNAPOLIS**  
PUBLIC WORKS


# DRIVEWAY ENTRANCE RADIUS TYPE

DATE: 01 MAY 08


R-DR-01



- NOTES:**
1. ALL CONCRETE TO BE 3600 P.S.I., 6" MIN. THICKNESS
  2. ALL DRIVEWAYS MUST MEET THE CURRENT CITY DRIVEWAY REGULATIONS AND NCDOT REQUIREMENTS FOR SPACING, SIGHT DISTANCE AND OFFSETS FROM PROPERTY LINES AND INTERSECTIONS.
  3. ALL CURB OR CURB AND GUTTER AND SIDEWALKS ARE TO BE REMOVED TO THE NEAREST JOINT BEYOND NEW SAW CUT OR JOINT TO BE PERPENDICULAR TO EDGE OF EXISTING PAVEMENT.
  4. FOR PLANTING STRIP LESS THAN 4-FEET, SLOPE SIDEWALK TO MEET GRADE OF ENTRANCE. SIDEWALK GRADE SHALL BE 12:1 MAX.
  5. RADIUS REQUIREMENTS -  
RESIDENTIAL: MIN.- 3'  
COMMERCIAL/INDUSTRIAL: MIN.-6' MAX.-30'
  6. NO UTILITIES PERMITTED IN DRIVEWAYS



DRIVEWAY CLASSIFICATION		
TYPE DRIVEWAY	MINIMUM	MAXIMUM
RESIDENTIAL	12'	20'
COMMERCIAL/INDUSTRIAL MULTI-FAMILY	24'	36'
COMMERCIAL/INDUSTRIAL ONE-WAY	15'	20'



SECTION B - B

SECTION A - A