



NOTES:

1. ONE FULL LENGTH OF WATER PIPE SHALL BE LOCATED SO THAT BOTH JOINTS WILL BE AS FAR FROM THE SEWER AS POSSIBLE.
2. IF UNABLE TO MEET MINIMUM SEPARATIONS, ENGINEER MUST DEMONSTRATE IMPRACTICABILITY IN ACCORDANCE WITH 15A NCAC 18C.0904 (c)