



NOTES:

1. MANHOLE RISERS AND CONE SECTIONS SHALL CONFORM TO ASTM C-478, LATEST REVISION.
2. TRANSITION RINGS SHALL HAVE A MINIMUM CLEARANCE OF 2'-0" ABOVE THE EFFLUENT OVERT ELEVATION.
3. SEE STD. 352 FOR DROP MANHOLE.
4. FLEXIBLE WATERTIGHT, SYNTHETIC RUBBER SLEEVES, WITH STAINLESS STEEL CLAMP; DRAW BOLT AND NUT; OR CAST-IN SLEEVE; OR "A" LOCK CONNECTION SHALL BE FURNISHED FOR EACH PIPE TO MANHOLE CONNECTION.
5. SEE SPECIFICATIONS FOR MANHOLE DIAMETER.
6. MAXIMUM HEIGHT OF GRADE ADJUSTMENT RINGS SHALL NOT EXCEED 12".

NOT TO SCALE