



NOTES:

1. VENT PIPE SHALL BE IN ACCORDANCE WITH WSACC SPECIFICATION SECTION 02605.
2. VENT OPENING TO POINT DOWNSTREAM.
3. TWO 3" X 3/8" STEEL STRAPS, AND 5/8" X 4" EXPANSION ANCHOR BOLTS SHALL BE USED TO SECURELY ANCHOR VENT.
4. THE FOLLOWING TABLE SHALL BE USED TO DETERMINE THE LENGTH OF THE STRAPPED LEG:

| HEIGHT OF VENT PIPE | LENGTH OF STRAPPED LEG |
|---------------------|------------------------|
| UP TO 6.00' | 3.00' |
| 6.01' TO 8.00' | 4.00' |
| 8.01' TO 10.00' | 5.00' |
| 10.01' TO 12.00' | 6.00' |
| OVER 12.01' | 7.00' |

NOT TO SCALE